



RESIDENTIAL ELEVATORS (RE) CONTROL SYSTEM CONTAINS THE 240 VAC AND 120 VAC DISCONNECTS, HOWEVER; GC / OWNER MUST PROVIDE DEDICATED CIRCUIT AND WIRE TO 4" x 4" BOX (1 FOR 240 VAC & 1 FOR 120 VAC) IN MACHINE SPACE PER DRAWING. SEE RE ELECTRICAL REQUIREMENTS BROCHURE FOR FURTHER DETAILS.

TYPICAL ELEVATION AND LAYOUT

(ADJACENT MACHINE ROOM)